




IPST10 for Windows
Barker Diacon IPST 10



COMPRESSION ACTIVATION TEST 11/6/2004 - 11:00:06 AM

SITE NAME: BEAVER VALLEY 1R16
OPERATOR NAME: NORMAN THOMAS
SOFTWARE VERSION: 4. 1. 3

SNUBBER TYPE: BERGEN PATTERSON 12x6.25
RATED LOAD: 1,747 kip
SERIAL NUMBER: 68284-20
WORK REQUEST: 200066370
HANGER ID: RC-HC-9B

TEST RESULTS

LOCKUP RATE:	2.54 ipm
BLEED RATE:	0.083 ipm
TEST LOAD:	1,211 kip
TEMPERATURE :	72.1 deg F.