




IPST10 for Windows  
Barker Diacon IPST 10



**COMPRESSION ACTIVATION TEST      11/6/2004 - 11:00:06 AM**

**SITE NAME: BEAVER VALLEY 1R16**  
**OPERATOR NAME: NORMAN THOMAS**  
**SOFTWARE VERSION: 4. 1. 3**

**SNUBBER TYPE: BERGEN PATTERSON 12x6.25**  
**RATED LOAD: 1,747 kip**  
**SERIAL NUMBER: 68284-20**  
**WORK REQUEST: 200066370**  
**HANGER ID: RC-HC-9B**

**TEST RESULTS**

<b>LOCKUP RATE:</b>	<b>2.54 ipm</b>
<b>BLEED RATE:</b>	<b>0.083 ipm</b>
<b>TEST LOAD:</b>	<b>1,211 kip</b>
<b>TEMPERATURE :</b>	<b>72.1 deg F.</b>